



IDAHO STATE FIRE MARSHAL'S OFFICE

700 W. STATE STREET, BOISE, IDAHO 83720
208-334-4370

FOOD TRUCK INSPECTION CHECKLIST

Name: _____	PASS	FAIL	N/A
Check that there is a clearance of at least 10 ft. away from buildings, structures, vehicles, and any combustible materials. [96:7.8.2; 96:7.8.3]			
Verify fire department vehicular access is provided for fire lanes and access roads. [1:18.2.4]			
Ensure clearance is provided for the fire department to access fire hydrants and access fire department connections. [1:13.1.3; 1:13.1.4; 1:13.1.5]			
Check that appliances using combustible media are protected by an approved fire extinguishing system. [96:10.1.2]			
Verify portable fire extinguishers have been selected and installed in kitchen cooking areas in accordance with NFPA 10. [96:10.9.3]			
Where cooking appliance produce grease-laden vapors, make sure the appliances are protected by listed fire-extinguishing equipment. [96:B.9.1.2]			
Ensure that workers are trained in the following: [96:B.15.1]: <input type="checkbox"/> Proper use of portable fire extinguishers and extinguishing systems [10:1.2] <input type="checkbox"/> Proper method of shutting off fuel sources [96:10.4.1] <input type="checkbox"/> Proper procedure for notifying the local fire department [1:10.14.9] <input type="checkbox"/> Proper procedure for how to perform simple leak test on gas connections [58:6.16, 58:6.17]			
Ensure that refueling is conducted only during non-operating hours. [96:B.18.3]			
Check that any engine-driven source of power is separated from the public by barriers, such as physical guards, fencing, or enclosures. [96:B.16.2.2]			
Make sure that exhaust from engine-driven source of power complies with the following: <input type="checkbox"/> At least 10 ft in all directions from openings and air intakes [96:B.13] <input type="checkbox"/> At least 10 ft from every means of egress [96:B.13] <input type="checkbox"/> Directed away from all buildings [1:11.7.2.2] <input type="checkbox"/> Directed away from all other cooking vehicles and operations [1:11.7.2.2]			
Ensure that all electrical appliances, fixtures, equipment, and wiring complies with the NFPA 70®.[96:B.18]			
Check that the main shutoff valve on all gas containers is readily accessible. [58:6.26.4.1(3)]			
Ensure that portable gas containers are in the upright position and secured to prevent tipping over. [58:6.26.3.4]			
Inspect gas systems prior to each use. [96:B.19.2.3]			
Perform leak testing on all new gas connections of the gas system. [58:6.16; 58:6.17]			
Perform leak testing on all gas connections affected by replacement of an exchangeable container. [58:6.16; 58:6.17]			

	PASS	FAIL	N/A
Document leak testing and make documentation available for review by the authorized official. [58:6.26.5.1(M)]			
Ensure that on gas system piping, a flexible connector is installed between the regulator outlet and the fixed piping system. [58:6.26.5.1(B)]			
Where a gas detection system is installed, ensure that it has been tested in accordance with the manufacturer's instructions. [96:B.19.2.1]			
Operate cooking equipment only when all windows, service hatches, and ventilation sources are fully opened. [96:14.2.2; 96:14.2.3]			
Close gas supply piping valves and gas container valves when equipment is not in use. [58:6.26.8.3]			
Keep cooking equipment, including the cooking ventilation system, clean by regularly removing grease. [96:11.4]			

Vendor Print Name:: _____

Vendor's Signature: _____

Vehicle License Plate Number: _____

Inspected By: _____ Agency: _____

Date: _____